



Pol. Ind. Lasao. Area Arandi, n°5  
20730 AZPEITIA (Guipúzcoa)  
Tel. 943 816800 – Fax: 943 816074  
Email: [cidemco@cidemco.es](mailto:cidemco@cidemco.es)  
<http://www.codemco.es>

REFERENCE NUMBER FOR REPORT: 16339-5  
Page 1 of 1

Date of Issue: 23<sup>rd</sup> October, 2008  
Date of Reception: 25<sup>th</sup> June, 2008

CLIENT: DRIZORO, S.A.

PETITIONER: Mr. FRANCISCO RODRIGUEZ

ADDRESS: C/ Primavera 50-52  
28850 TORREJÓN DE ARDOZ

REFERENCE:  
DELIVERED MATERIAL: "MAXSEAL SUPER"  
25 KG OF WATERPROOFING MORTAR "MAXSEAL SUPER"

REFERENCE	STANDARD	TITLE	RESULT
"MAXSEAL SUPER"	UNE-EN ISO 7783-1:2000 UNE-EN ISO 7783-2:1999	Determination of the water vapour transmission rate (permeability)	$V = 340,22 \text{ g/m}^2\cdot\text{day}$ $S_D = 0,06 \text{ m}$



(Illegible signature and Stamp)  
Mr. Javier GARCÍA JACA  
Director of Material Department